# **Chapter 3** Expansion of FBS-PLC

If the I/O point of the. Main unit of the applied FBs-PLC is not enough for a specific application, then can expand it with the additional expansion units/modules. Besides I/O point there also have the requirements to expand the communication port in some occasions.

### 3.1 I/O Expansion

The expansion of FBs-PLC I/O consists of Digital I/O ( DI/O, which status is represented by a single bit) and the Numeric I/O (NI/O, which status is represented by a 16-bit Word). Either the DI/O or the NI/O expansion is realized through expansion units or modules cascaded thru the usage of the "I/O Output Expansion Connector" located at the right side of FBs-PLC or expansion unit/ module.

The I/O points of FBs-PLC system are limited to 512 points of DI/O (256 points for DI and DO, respectively), 128 words of NI/O (64 words for NI and NO, respectively). Besides this there are two limits imposed by hardware: ①. A maximum number of 32 units or modules can be used in the expansion. ②. The total length of the expansion cables cannot exceed 5 meters.

## ♠ Caution

- 1. If the I/O points of the application system exceed one of the limitations(256 DI,256 DO,64 NI, 64 NO), while startup the main unit of FBs-PLC will treat this as an illegal I/O configuration, which in return will flag as an error situation by turn on the "ERR" LED and put the error code in Y0~Y3 LED(refer the page 8-2, Chapter 8). The corresponding error code will also be indicated in the CPU status register (R4049).
- 2. The maximum number of expansion units/modules of FBs-PLC is 32. Beyond this numbers will be treated as an invalid I/O configuration and the main unit will stop its operation, which in return will flag as an error situation by turn on the "ERR" LED and put the error code in Y0~Y3 LED(refer the page 8-2, Chapter 8). The corresponding error code will also be indicated in the CPU status register (R4049).

## ♠ Warning

 The maximum length of the I/O expansion cable for FBs-PLC is 5 meters. Cables longer than that will cause incorrect I/O operation because of excess signal delay in hardware or noise pickup, resulting in damage to equipment or posing hazard to operating personnel. Since this kind of situation cannot be detected by the PLC main unit, users are advised to take extra cautions and necessary measures.


#### 3.1.1 Digital I/O Expansion and I/O Numbering

Digital I/O means I/O with the discrete type status, including digital input (with initial X in DI numbering) and digital output (with initial with Y in DO numbering). The DI and DO of FBs-PLC can both be expanded up to 256 points (numbered as X0~X255 and Y0~Y255, each with 256 points).


The status of input contacts (X0~X255) of PLC come from the input signal connected to the digital input terminal block on main unit or expansion unit/module; while the status appears at digital output terminal block of main unit and expansion unit/module reflects the digital output relay (Y0~Y255) status inside PLC.

On FBs-PLC main unit, at the position below the digital input terminal block and the position above the output terminal block, there have labels indicate the corresponding signal name. They label each terminal with numbers representing the corresponding digital input contact Xn and digital output relay Yn. In the example of the main unit in FBs-24MCR, the corresponding digital input contacts on the input terminal block are labeled X0~13, and the corresponding digital output relays on the output terminal block Y0~Y9. Users only need to locate the printed label for each terminal to find out its I/O number. The LED status display region also indicates the ON/OFF status for all DI(X0~X13) and DO(Y0~Y9)

on the main unit. Users can easily find each terminal with its I/O number and LED status indication, as shown in the figure below using X10 and Y6 as an example:



While the various expansion units/modules other than the main units have the same printed labels on the input/output terminals as the main units do, these labels are only relative I/O numbers, different from the absolute I/O numbers on main units. The number of a terminal only represents its order on the expansion unit/module. For example, the first contact is X1 or Y1, the second X2 or Y2, etc. All numbers on the expansion unit/module begin with 1. The actual number of digital input contact or the output replay, however, is determined by summing the numbers on all previous expansion units/modules and the main unit. See the following figure and its calculation.



As shown in the above figure, because the top X numbers of the previous two units are 23 and 14, respectively, the number of input contact X12 on second expansion unit should be:

$$X (23+14+12) = X49$$

#### 3.1.2 Numeric I/O Expansion and I/O Channel Mapping


The numeric I/O in FBs-PLC treat 16 single-bit data as one 16-bit numeric data (Word) ranging from the 0~65535. Since all numeric data of FBs-PLC are stored in the register inside PLC (16-bit width), therefore numeric I/O is also called register I/O. The Input Register (IR) has 64 Word (R3840 ~ R3903) for inputs from external numeric input (NI) module, and the Output Register (OR) also has 64 Word (R3904 ~ R3967) for outputs to external numeric output (NO) module.

Analog Input Module, Temperature Module, and Thumbwheel switch multiplex input module are of Numeric input (NI) modules which use input register (IR) to convey the status. Analog Output Module, 7 Segments Display Module are of Numeric output (NO) modules which output is directly from the Output register (OR). The Analog Input, Temperature Input, and Analog Output is of analog voltage or current, while the Thumbwheel switch Input or 7 Segments Display Output uses user-friendly BCD number signal. Either the magnitude of voltage or current or the value of BCD number is represented by the 16-bit value of the corresponding register. The corresponding current/voltage signal or BCD value of any IR or OR on the NI/O module is named as a Channel (CH). The channels on the NI module are called numeric input channels (NI channels) and those on NO module numeric output channels (NO channels). The number of IR/OR used by NI and NO channels on each module varies depending on the module type or working mode. The following table lists the numbers of IR and OR used by NI and NO channels on each NI/O module:

NI/O		NO	Number of	Number of	
Module Name	NI Channel Label	Channel	IR occupied	OR occupied	Note
Module Name		Label	(Word)	(Word)	
	CH0		1		
	CH1		1		
FBs-6AD	CH2		1		
LDS-0AD	CH3		1		
	CH4		1		
	CH5		1		
FBs-2DA		CH0		1	
FD5-2DA		CH1		1	
		CH0		1	
FBs-4DA		CH1		1	
1 D3-4DA		CH2		1	
		CH3		1	
	CH0		1		
	CH1		1		
FBs-4A2D	CH2		1		
1 03-4/20	CH3		1		
		CH0		1	
		CH1		1	
	VIO(V)		1		The voltage and
	110(1)				
	VI1(V)		1		current inputs can't be used at the
FBs-B4AD	II1(I)				same time in the
1 03-0 <del>4</del> A0	VI2(V)		1		same channel. It
	112(1)				only one (V or I)
	VI3(V)		1		available.
	113(1)		'		
		VO0(V)		1	Both voltage and
FBs-B2DA		100(1)			current will be
1 50 52570		VO1(V)		1	outputted at the
		IO1(I)			same time.

	VIC	)(V)		,		The voltage and
		110(1)		1		current inputs can't
		(V)	1		1	be used at the
		,	1			same time in the
	II1(I)			1		same channel. It
FBs-B2A1D						only one (V or I)
						available.
			VO0(V)			Both voltage and current will be
			100(1)		1	outputted at the
			100(1)			same time.
FBs-32DGI	Unla	beled		8		1 CH only
			0110		3(D)	
FBs-7SG1			CH0		4(ND)	
			CH0	_	3(D)	D: decode mode
FD 7000					4(ND)	ND: non-decode
FBs-7SG2			0114		2(D)	mode
			CH1		4(ND)	
FDo 2TC	С	H0		1		1 CH only
FBs-2TC	С	H1		1		
FBs-6TC/6RTD	CH0~CH5			1		1 CH only
FBs-16TC/16RTD	CH0~CH15			1		1 CH only
	2A	CH0		1		
	ZI	CH1		1		
FBs-2A4TC		CH0		2		
1 03-2/1-10	4TC	CH1				
	410	CH2				
		CH3				
	2A 4TC	CH0		1		
		CH1		1		
FBs-2A4RTD		CH0		2		
1 D3-2A4K1D		CH1				
		CH2				
		CH3				
FBs-6NTC	CH0~CH5			1		
FBs-1LC	CH0			1		
FBs-4PT	CH0			1		
	CH1			1		
	CH2			1		
	CH3			1		
					1	Or unused

The corresponding IR or OR number calculation of the NI/O module starts from the first expansion unit/module(main unit itself does not have any NI/O). The first NI channel corresponds to the first IR register (R3840). Adding R3840 with the number of IR used by the first NI channel gives the IR number of the second NI channel. Adding the IR number of the second NI channel with the number of IR used by the second NI channel gives the IR number of the third NI channel. All other numbers can be obtained accordingly. Similarly, the first NO channel corresponds to the first OR (R3904). Adding R3904 with the number of OR used by the first NO channel gives the OR number of the second NO channel. (In the cumulative calculation of NI channels, care only for NI channels and disregard DI/O and NI. Similarly, in the case of NO channels, disregard DI/O and NI channels.) The following figure helps users find out the relation between NI/O channels and PLC's IR and OR.



During the startup stage, FBs-PLC will automatically detect the types and CH numbers of expansion units/modules. While operation, the FBs-PLC will read the CH input values from the NI module and stores them into corresponding IR(R3804 ~ R3903) and outputs OR values (R3904~R3967) to channels on the NO module. No pre-configuration or setting by users is required.

### 3.2 Expansion of Communication Port

The main unit of FBs-PLC has one built-in communication port (port 0, with optional USB or RS232 interface). Expansion of communication ports can be achieved by employing Communication Board (CB) or Communication Module (CM). The available models of CB and CM for FBs are:

		Model Number	Specifications	
	,	FBs-CB2	RS232 (port2) communication board	
	Commun	FBs-CB22	2 RS232 (port1 & port2) communication boards	
	unm	FBs-CB5	1 RS485 (port2) communication board	
(CB)	ication	FBs-CB55	2 RS485 (port1 & port2) communication boards	
		FBs-CB25	1 RS232 (port1) + 1 RS485 (port2) communication board	
	Board	FBs-CBE	1 Ethernet communication board	
	<u>~</u>	FBs-CBCAN	1 CANopen® communication board	

ဂ	FBs-CM22	2 RS232 (port3 & port4) communication modules	
Mod	FBs-CM55	2 RS485 (port3 & port4) communication modules	
nunio	FBs-CM25	1 RS232 (port3) + 1 RS485 (port4) communication expansion module	
nunication ule (CM)	FBs-CM25E	1 RS232 (port3) + 1 RS485 (port4) communication module with Ethernet	
Š	FBs-CM55E	FBs-CM55E 1 RS485 (port3) + 1 RS485 (port4) communication module with Ethernet	

Communication boards, which can be directly installed on FBs main units, are employed for expansion of communication ports port1 and port2. Communication modules are independent modules used for the expansion of communication ports port3 and port4 and need to be mounted against the left side of FBs main unit and connected to the main unit via a 14pin connector. The labels of communication ports are marked on the cover plate of communication boards and modules, from which users can easily identify each port. Except that the built-in communication port (Port0) can only be used for USB or RS 232 interface, all the other ports (Port 1~4) can be used for RS232 or RS 485 interface in CB and CM. The following figure shows an example of expansion of 5 (maximum allowed number) communication ports (CB22+CM25E):

#### The most expansion of communication port diagram

